

FUZZY LOGIC BASED OPTIMIZATION FOR LOAD SCHEDULING TO MANAGE GRID OUTAGES IN DEVELOPING COUNTRIES

Amit S. Closepet

Spectrum Consultants, Bangalore, India 560001
Amit.s.closepet@spectrumconsultants.co.in

ABSTRACT - This paper describes the significant cost saving opportunities for consumers in developing countries by the use of computational intelligence and demand-side-management techniques to mitigate the massive use of diesel back-up during grid outages. Application of load scheduling optimization is investigated during scheduled power outages, for residential consumer in India. The specific load shifting approaches explored include a day ahead predicted load schedule which is generated by performing a DSM referring to the forecasted day ahead outage. Whereas in reality the predicted may not match the actual outage, thus in these cases a fuzzy logic rule base is referred on real time basis to take corrective action & reach the best optimal load schedule possible to attain the lowest cost. The load types modeled include passive loads and schedulable, i.e. typically heavy loads. It is found that this multi-level DSM schemes show excellent benefits to the consumer. The maximum diesel savings for the consumer due to load shifting can be approximately ranging from 45% to as high as 75% for a flat-tariff grid. The study also showed that the actual savings potential depends on the timing of power outage, duration and the specific load characteristics.

Keywords: Fuzzy Logic, load switching, DSM

INTRODUCTION

Demand-side-management (DSM) policies are being formulated by various stakeholders in India and other developing countries. These policies are specifically targeted to overcome large energy demand-supply gaps, to provide inclusive and reliable power for entire populations. For example, in India, load scheduling has recently been implemented successfully for the agricultural sector. As in developed countries, load scheduling is driven by the utility for peak clipping of demand, load shifting for energy conservation and/or supporting load growth. In this work, our aim is to highlight the urgent need for demand-side-management policies to address one of the major unaddressed challenges for a consumer in a developing country which is the problem of frequent power outages. DSM solutions and policies need to be developed, validated and framed to enable the consumer get reliable power and reduce his dependence on expensive diesel back-up systems. The highly stochastic nature of the power grid (Fig. 1) in developing economies with relentless power cuts forces consumers to rely heavily on diesel back-up systems for business continuity, risk mitigation and load execution. Major cost investments are required for both installation and operation diesel back-up systems. Recent articles [1-4, 17] have shown that, in some cases, cost can run as much as high as 50% of the customer's annual power budget. In this study, we explore the use of demand management techniques that will enable the consumer mitigate power outages, cut the dependence on diesel back-up and provide significant cost savings to the consumer.




Figure 1 Stochastic Grid in Developing Countries

Tables 1(a)-(b) in [18] provide power outage data for several major cities in India and in other developing economies such as Africa, Philippines, South America and observe that power outages range from 2 hours to more than 10 hours a day. Power blackouts typically result in total loss of power to large parts of the entire city to large districts. Different scenarios and causes for planned/unplanned power outages in India are described in [4-5]. Due to this grid unreliability, the market for genset and UPS systems in India is worth several billion dollars and growing at a rapid 20% annual rate. In India, residential consumers sometimes pay large premium (~3X) over grid power due to use of expensive back-up systems [4,5]. Service businesses (e.g. photocopier centers, medical diagnostic labs, service apartments, wedding halls etc.) charge higher rates to the consumer during power outages. Home owners association (HOA) in apartment complexes are faced with large diesel bills due to a shared gen-set and these additional costs are periodically collected from the consumer. In hospitals, the continuous power is ensured by using UPS systems. According to the Bureau of Energy Efficiency in India [6], to deliver a sustained economic growth rate of 8% to 9% through 2031-32 and to meet life time energy needs of all citizens, India needs to increase its primary energy supply by 3 to 4 times and electricity generation capacity about 6 times. Based on these aforementioned statistics and the present high inefficiencies in the grid, it is likely that power outages are here to stay unless DSM policies are directly targeted at mitigating the large power outages for all consumers.

We explore two specific DSM techniques manage outages for a residential load in India. Our goals are to minimize the quantum of loads executed during outage by load-shifting and deliver costs savings by significantly reducing the consumption of diesel. Decisions to whether to execute the load with diesel or to compromise load the altogether are often encountered for the emerging market consumer. Specific power outages are announced well in advance by the utility publicly for each specific locality. For example, in the city of Chennai in South India, the local utility has recently announced a 2 hour power outage daily for the months of March to June 2012.

In this study, application of load scheduling optimization is investigated during scheduled power outages, for residential consumer in India. The specific load shifting approaches explored include a day ahead predicted load schedule which is generated by performing a DSM referring to the forecasted day ahead outage. Whereas in reality the predicted may not match the actual outage, thus in these cases a fuzzy logic rule base is referred on real time basis to take corrective action & reach the best optimal load schedule possible to attain the lowest cost. The load types modeled include passive loads and schedulable, i.e. typically heavy loads. It is found that this multi-level DSM schemes show excellent benefits to the consumer.

Implementation of a load scheduler can be extremely difficult for a consumer in a developing country. The reasons are many including ease of use, availability of controllable loads etc. In India, consumers typically switch off their heavy loads during a power outage and execute them after power is restored. In newer apartment buildings, the heavy load lines are usually a separate circuit (e.g. 15 amps) and the apartment back-up generator simply doesn't provide power to these lines. All heavy and shiftable loads are often connected to the 15 amp line. This technique of casually rescheduling heavy loads results in unexpected peaks for the utility as soon as power is restored. While the actual implementation of the load control and scheduling can be accomplished either by the utility or the end consumer themselves, the aim of the DSM policy needs to be consumer-centric. In other words, the consumer needs to always have the flexibility of load selection and execution without yield controlling to the utility.

LITERATURE SURVEY

Numerous studies have focused on the impact of unreliable grids on consumer cost as seen in the following works: An in-depth investigation into the impact of power outages for consumers and businesses in Africa is performed in [4]. This study also assesses the economic consequences of the unreliable grids. A report on real power cost in India [5] reveals that the overall intent of providing cheap and affordable power to the consumers in the country is noble, but if the supplies are inadequate or unreliable, the consumers could actually end up paying a much higher price. A report from United Nations [6]

provides directions to expand access of modern energy services at the household level. An application of combined model of extrapolation and correlation techniques for short term load forecasting of an Indian substation is presented in [7]. Specific opportunities for DSM in the Indian scenario are presented in [8]. Low-cost energy generation using bio-mechanical energy is presented in [9] and this provides a technology options for both off-grid users as well as on-grid users who have unreliable power. The use of casual scheduling loads with time-varying prices using stochastic dynamic programming is studied in [11] and its effect on consumer cost are reported.

In [13], a power scheduling protocol for demand response in smart grid system is explored which focuses on limiting the allowable power loads. Algorithmic enhancements to a scheduler for residential DSM are presented in [15].

SIMULATION APPROACH AND ANALYSIS METHODOLOGY

The MATLAB methodology to model the demand side management optimization and scheduling are described in this section. The MATLAB code is structured in such a manner that it fetches all the input data from various excel files, these excel files can be edited for demand, for the individual load power characteristics, for the load start time, the load run time, for forecasted outage start time & outage duration etc., Once these inputs are ready we can go to the MATLAB GUI to run the code.

Once the code is run for a forecasted outage it results in a new load schedule for the following day depending on the outage. Due to the unreliable grid, we have assumed an error in the outage scenario of maximum of 1 hour on either sides of the forecasted outage. Thus to simulate this unreliable grid we do a real time fuzzy logic based DSM on the loads by creating an error in the outage either in the outage start time or outage end time or even both. Thus depending on the actual outage the fuzzy logic rule base is referred for a further correction in the load schedule to reach to the best optimal cost.

The baseline costs assumed for the grid is 5c/KWhr (residential) and the baseline diesel costs assumed in the simulation are 20c/KWhr. As the power characteristics of the loads are not constant we have divided the day into multiple of a 5 minutes chunk, so 24 hours is considered as 288 chunks, by doing this we can be very accurate in calculating the effective cost, for a better and simple understanding we have assumed all the heavy loads considered in the paper i.e. 3 Geysers, 1 washing machine, 1 dishwasher & a dryer to have flat power characteristics curves.

OPTIMIZATION EQUATIONS

The cost minimization equation is as follows:

Input parameters

$L_{PASSIVE}(t) \rightarrow$ Passive Load at time t

$L_{SHIFT,i}(t) \rightarrow$ Shiftable Load i at time t

Total Load $\sum(L(t)) = \sum L_{PASSIVE}(t) + \sum L_{SHIFT,i}(t)$ for $i=1,n$

$t_G \rightarrow$ Grid available time for a day

$t_B \rightarrow$ Diesel usage time in a day

$C_G(t_G) \rightarrow$ Cost per unit with grid

$C_B(t_B) \rightarrow$ Diesel cost per unit


Total cost per unit at time $t \rightarrow C(t)$

$= C_G(t_G) + C_B(t_B)$

Total Cost $C_{TOTAL} = \sum C(t)L(t)$ for $t = 0,24$

$C_{OPT} = \text{Min}(C_{TOTAL})$

Algorithm: - Finding optimal load schedule



$L1_{NrST}$ → Normal Start Time Of Load(1)

$L1_{EST}$ → Earliest Start Time Of Load(1)

$L1_{LST}$ → Latest Start Time Of Load(1)

$L1_{RT}$ → Run Time Of Load(1)

$L1_{NrET}$ → Normal End Time of Load(1)

$$L1_{NrET} = L1_{NrST} + L1_{RT}$$




Fig A: Load Schedule Constraint

FigA speaks about how every shiftable load is normally scheduled & also what are its constraints i.e. the load cannot be shifted randomly during the day but has an earliest start limit & also a latest start limit. Hence any shifting of these loads has to be done between this time frame.




Fig A(2): Expected Outage For The Following Day

b_{ExST} → Expected Outage Start Time

b_{ExET} → Expected Outage End Time

In Fig A(2) we can clearly observe that the outage is expected to affect the load, thus this load has to be shifted, Thus the load is scheduled to a new start time either before the outage or after the outage, this completely depends on the load constraints & also the runtime of the load, if the gap is available on both sides of outage, the algorithm chooses to shift the load before the outage as it is safer to execute the load beforehand, rather to risk the execution of the load with the unreliable grid supply.

This is seen in Fig A(3).




Fig A(3): day Ahead Load Shift Schedule

$L1_{NeST}$ → New Expected Load Start Time

$L1_{NeET}$ → New Expected Load End Time

$$L1_{NeET} = L1_{NeST} + L1_{RT}$$




Fig A(4) Actual Outage

$b_{AcST} \rightarrow$ Actual Outage Start Time

$b_{AcET} \rightarrow$ Actual Outage End Time

In Fig A(4) we can observe that the actual outage is overlapping the new scheduled start time of the load, this data is obtained from the real time supply sensors.

Now the real time Fuzzy Logic Rule base for this kind of a scenario where a second shift of the load is required comes into action.

The rule mentioned below comes into action & the load is shifted at the b_{AcET} .

If $b_{AcST} \leq L1_{NeST} \& L1_{NeST} \leq b_{AcET} \leq L1_{NeET} \Rightarrow 2^{nd}$ Shift




Fig A(5) Actual Load Schedule

$L1_{AcST} \rightarrow$ Actual Load Start Time

Thus the $L1_{AcST} = b_{AcET}$

All the shiftable loads undergo this exercise to get the best possible optimal solution to attain the least cost, by finally reaching $C_{OPT} = \text{Min}(C_{TOTAL})$

RESULTS

In this section, key results and benefits from the MATLAB Tool for the 2 level optimization of load-scheduling of residential loads for diesel mitigation are discussed.

Through the forecast the expected outage can be generated, thus this expected outage will lead to a first level demand side management & hence an expected new load schedule.

Table 1 shows the forecasted diesel savings of various different outage durations starting at 2 different peak times in a day. For the case of a 2 hours outage starting at 1pm the expected diesel savings of as high 65.95% can be seen.

Table 1 Forecasted Diesel Percentages For Various Outages

Forecasted Diesel Percentage Savings				
Start time/ Outage duration	2 hours	4 hours	6 hours	8 hours
7PM	59.80	52.79	54.41	58.60
1PM	65.95	53.52	35.58	29.62

The following fig 1(a) explains the aggregate reference load curve i.e. the original load curve, here we can see the 2 peaks prominently. The break-up of the load will be seen in Fig 2.




Fig. 1 Original Day Ahead Load Curve




Fig. 2 Individual Load Schedule

Next the Fig 3 explains the expected outage leading to a load shift and finally a new expected load schedule for the next day .

Comparing Fig.4 & Fig 2 we can clearly notice that for an expected outage of 1pm to 3pm the first level DSM will shift the dishwasher & dryer to a new time & will schedule them to start at 3pm.




Fig. 3 Expected Load Schedule




Fig. 4 Expected Individual Load Schedule

Due to the unreliable grid there could be many scenarios that are very close to the forecasted outage. Table 2 shows 25 different cases which are very close to the expected outage

Table 2 Shows 25 Different Actual Cases Around a Single Expected 2 hours Outage Case

TABLE FOR 2 HOURS BLACKOUT				
SL NO	TYPE OF CASE	TIME OF BLACKOUT	% SAVINGS	TYPE OF SHIFT
1	ACTUAL CASE	12PM TO 2PM	75.0	Green
2	ACTUAL CASE	12PM TO 2:30PM	70.9	
3	ACTUAL CASE	12PM TO 3PM	67.8	
4	ACTUAL CASE	12PM TO 3:30PM	65.4	
5	ACTUAL CASE	12PM TO 4PM	63.5	
6	ACTUAL CASE	12:30PM TO 2PM	55.3	Pink
7	ACTUAL CASE	12:30PM TO 2:30PM	53.8	
8	ACTUAL CASE	12:30PM TO 3PM	52.8	Green
9	ACTUAL CASE	12:30PM TO 3:30PM	52.1	
10	ACTUAL CASE	12:30PM TO 4PM	51.5	
11	ACTUAL CASE	1PM TO 2PM	75.0	Pink
12	ACTUAL CASE	1PM TO 2:30PM	69.6	
13	EXPECTED CASE	1PM TO 3PM	66.0	Green
14	ACTUAL CASE	1PM TO 3:30PM	63.3	
15	ACTUAL CASE	1PM TO 4PM	61.3	Pink
16	ACTUAL CASE	1:30PM TO 2PM	75.0	
17	ACTUAL CASE	1:30PM TO 2:30PM	66.0	
18	ACTUAL CASE	1:30PM TO 3PM	61.3	Green
19	ACTUAL CASE	1:30PM TO 3:30PM	58.4	
20	ACTUAL CASE	1:30PM TO 4PM	56.5	Pink
21	ACTUAL CASE	2PM TO 2:30PM	46.7	
22	ACTUAL CASE	2PM TO 3PM	46.7	
23	ACTUAL CASE	2PM TO 3:30PM	46.7	Green
24	ACTUAL CASE	2PM TO 4PM	46.7	

Here we have assumed a maximum of 1 hour error in the outage on either sides of the expected outage.

The last column in Table 1 shows the type of shift, i.e. the green colour shows that those outages are leading to a real time second shift. The pink colour shows that these outages are not interfering the first load schedule & hence need no real time shifting. The Fig 5 shows the variation in the outage from the expected outage, In this particular case the actual outage starts at 12pm to 3:30pm. This case involves a real time fuzzy logic based shift, this can be observed at an aggregate level in Fig 5 & at an individual level in Fig 6




Fig. 5 Fuzzy Logic Based Real Time Optimized Load Curve




Fig. 6 Fuzzy Logic Based Real Time Optimized Individual Load Curve

From Table 2 we can see that this real time shifting of loads will lead to a diesel savings percentage of 65.4% Here we can observe that the real time shift of washing machine, dryer & dishwasher which was previously scheduled to start at 12pm, 3pm & 3pm respectively will now start at 3:30pm. Similarly Table 3 shows the actual 25 cases that are possible around an expected outage of 4 hours starting at 1pm. The expected diesel savings from table 1 is 53.52 % where as in reality due to the unreliable grid the savings percentage can vary from 30.42 % to 63.51 %.

Table 3 Shows 25 Different Actual Cases Around a Single Expected 4 hours Outage Case

TABLE FOR 4 HOURS BLACKOUT				
SL NO	TYPE OF CASE	TIME OF BLACKOUT	% SAVINGS	TYPE OF SHIFT
1	ACTUAL CASE	12PM TO 4PM	63.51	
2	ACTUAL CASE	12PM TO 4:30PM	59.79	
3	ACTUAL CASE	12PM TO 5PM	56.63	
4	ACTUAL CASE	12PM TO 5:30PM	54.34	
5	ACTUAL CASE	12PM TO 6PM	52.22	
6	ACTUAL CASE	12:30PM TO 4PM	51.71	
7	ACTUAL CASE	12:30PM TO 4:30PM	48.28	
8	ACTUAL CASE	12:30PM TO 5PM	45.02	
9	ACTUAL CASE	12:30PM TO 5:30PM	43.48	
10	ACTUAL CASE	12:30PM TO 6PM	41.67	
11	ACTUAL CASE	1PM TO 4PM	61.29	
12	ACTUAL CASE	1PM TO 4:30PM	57.14	
13	EXPECTED CASE	1PM TO 5PM	53.52	
14	ACTUAL CASE	1PM TO 5:30PM	51.01	
15	ACTUAL CASE	1PM TO 6PM	48.72	
16	ACTUAL CASE	1:30PM TO 4PM	56.52	
17	ACTUAL CASE	1:30PM TO 4:30PM	51.49	
18	ACTUAL CASE	1:30PM TO 5PM	49.10	
19	ACTUAL CASE	1:30PM TO 5:30PM	44.44	
20	ACTUAL CASE	1:30PM TO 6PM	41.94	
21	ACTUAL CASE	2PM TO 4PM	46.67	
22	ACTUAL CASE	2PM TO 4:30PM	40.58	
23	ACTUAL CASE	2PM TO 5PM	35.90	
24	ACTUAL CASE	2PM TO 5:30PM	32.94	
25	ACTUAL CASE	2PM TO 6PM	30.43	

CONCLUSIONS

Use of multi-layer load-shifting techniques to mitigate power outages in developing countries shows significant cost savings potential by massive reduction in diesel consumption by load-scheduling. The maximum diesel reduction for the consumer due to load shifting during power outages can be approximately 45% to 75% for a flat-tariff grid. The study also showed that the actual savings potential depends on the timing of power outage, duration and the specific load characteristics. As diesel prices increase, the economic benefits of load-shifting are also increase correspondingly. For blackouts of lesser duration (e.g. 2 hrs) the benefits in saving diesel can be as much as 75%. For longer blackouts (e.g. 8 hours), the diesel savings is in the range of 20%-60%. DSM policies for developing countries should consider specific approaches to mitigate power outages and provide relief to customers. Clearly, challenges exist in implementation of DSM policies since most consumers in India and frugal markets have outdated appliances that are unintelligent with a severe need to develop low-cost smart network-controllable solutions as a retrofit.

REFERENCES

- [1] Power Annual report 2009-10, CES, Govt. India
- [2] "Energy and the Millennium Development Goals in Africa", 2006, UN World Summit
- [3] Development Goals in Africa Electricity Supply Monitoring Initiative(ESMI), Prayas, India
- [4] Vivien Foster, JevgenijsSteinbuks, "Paying the Price for Unreliable Power Supplies" In-House Generation of Electricity by Firms Africa, 2009
- [5] "Real cost of power" 2009, Universal Consulting
- [6] "Energy poverty" World Energy Outlook for UN General Assembly on Millennium Goals 2010
- [7] RabindraBehera, BibhuPanigrahi, BibhutiBhusan, "Hybrid Short Term Load Forecasting Model of Indian Grid" Energy Power Engg, 2011

- [8] S. Padmanaban & Ashok "Electricity DSM In India Strategic & Policy Perspective"
- [9] VenkatNatarajan, AmitBaxi, RamanathPadmanabhan, Vincent Mageshkumar, "Low-Cost Bio Mechanical Energy Generator for Off-Grid Users in Emerging Markets" 2011 IEEE GHTC
- [10] Report, "Action Plan for Energy Efficiency", 2012, Bureau Energy Efficiency, India
- [11] Tung Kim and Vincent Poor, "Scheduling Power Consumption with Price Uncertainty", 2011, IEEE Trans Smart Grid
- [12] Amir-Hamed Mosenian-Rad and Alberto Leon-Garcia, "Optimal Residential Load Control With Price Prediction in Real-Time Electricity Pricing Environments", 2010, IEEE Trans. Smart Grid
- [13] M. A. A. Pedrasa, T. D. Spooner, and I. F. MacGill, "Scheduling of demand side resources using binary particle swarm optimization," IEEE Trans. Power Syst., vol. 24, no. 3, Aug. 2009.
- [14] K. Herter, "Residential implementation of critical-peak pricing of electricity," Energy Policy, vol. 35,, Apr. 2007.
- [15] Michael Angelo A. Pedrasa, Ted D. Spooner, & Iain F. MacGill, "Coordinated Scheduling of Residential Distributed Energy Resources to Optimize Smart Home", IEEE Trans. Smart Grid, Vol. 1, Sept. 2010
- [16] "Energy Infrastructure in India" 2011, World Bank Country Report
- [17] VenkatNatarajan, Amit S. Closepet, "Statistical Analysis of Cost of Energy Due to Power Outages in Developing Countries", 2012, Future Computing Conf Submission, France
- [18] VenkatNatarajan, Amit S. Closepet, "Demand-Side Approaches To Manage Electricity Outages In Developing Countries", 2012, ENERGYCON, Florence, Italy